

DISTRICT WATER TESTING LABORATORY, FEROZPUR
Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfzr@gmail.com

TC 14027

TEST REPORT

Name & Address of Customer : Principal D.C.M International School ,Zira Road, Ferozpur City Punjab		Customer Reference No.	No : DCMI/ADM/071 Dated : 28/10/2025
		Sample Submitted by	Bhupinder Singh
		Date of Sample Receipt	30/10/2025
		Analysis Starting Date	30/10/2025
		Analysis completion Date	31/10/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC10375250000587F	Sample Type :	Water
Test Report No.:	DWTL/FZR/2526/00256	Date of Issue :	31/10/2025
Registration no.:	DWTL/FZR/REG2526/01122	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	D.C.M International School ,Zira Road, Ferozpur City Punjab / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Ferozpur	District :	Ferozpur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.89@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.8	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T.Alkalinity(CaCO ₃)	80	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T.Hardness(CaCO ₃)	68	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2023) EDTA Method
9	Calcium(Ca)	24	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	1.9	30	100	mg/l	APHA (24th Ed.2023) Method: 3500 Mg+2 B By Calculation Method
11	Chloride(Cl)	10	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, I=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju
Mrs. Manju
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Ferozpur

End of the Test Report

DISTRICT WATER TESTING LABORATORY, FEROZPUR
Department of water supply and sanitation, zira gate, circular road, Ferozpur
dwtlfzr@gmail.com

To,

Principal
D.C.M International School ,Zira Road, Ferozepur City Punjab


No.: DWTL/FZR/2526/00256 Dated : 31/10/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DCMI/ADM/071 Dated: 28/10/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 30/10/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Ferozpur

D/A : Test Report


Authorized Signatory
For, District Water Testing Laboratory
Ferozpur